

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. \_\_\_\_\_ Dated: \_\_\_\_\_  
It is certified that an inspection team headed by Dr. Ashish Gursain  
(Name of Officers with designation) from CHC Gandiyal PHED  
inspected the Atal Utkrishit GIC Kanskhet  
(Name & Address of the school) on 02.06.2025 (date of inspection) and on the basis of  
Water Test Report (Attached) bearing no. 02/WR/SOLWOTMUS/2025-26 dated 26.05.25  
of SALWOTMUS, Solpauli (PHED Lab) certified that the  
Atal Utkrishit GIC Kanskhet (Name of school) has safe drinking water  
facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the  
Central/ State/ U.T. Govt.

This certificate is valid till 06 mth

Signature with Seal: \_\_\_\_\_  
Name: Dr. Ashish Gursain  
Designation: Chief Officer, PHED Gandiyal  
Name & Address of the Officer: CHC Gandiyal, P.O. Gandiyal, P.O. Gandiyal

To  
ATAL UTKRISHIT GOVT  
INTER COLLEGE KANSKHET  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

दीपक सिंह  
अध्यक्ष  
विद्यालय प्रबंधन समिति

Ref  
प्रधानाचार्य  
एल उत्कृष्ट रा० ड० का० कास  
कल्पीखाल, पौड़ी गढ़वाल

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by

Sushil Kumar, Technical Manager

(Name of Officers with designation) from SDL WATML, Satpuli PHED

inspected the Atal Utkrishi Govt. Inter College, Kanskhet

(Name & Address of the school) on 24.05.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 02/025/SDLWATML/2025-26 dated 26/05/2025

of SDL WATML, Satpuli (PHED Lab) certified that the

Atal Utkrishi Govt. Inter College, Kanskhet Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 06 months.

Sushil Kumar  
TECHNICAL MANAGER  
SUB-DIVISIONAL LEVEL  
WATER QUALITY TESTING  
& MONITORING LABORATORY

Signature with Seal: UJS SATULI, PAURI, GARHWAL

Name

Sushil Kumar

Designation

Technical Manager

Name & Address of the Office / Department: SDL WATML

Uttarakhand Jal Sansthan, Satpuli

To

ATAL UTKRISHI

GOVT. INTER COLLEGE, KANSKHET

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

दीपक सिंह

अध्यक्ष

निद्राल प्रबन्धन समिति

Raj

प्रधानाचार्य

एल उत्कृष्ट रा० ड० का० कास०  
कल्जीखाल, पोड़ी गढवाल



Sub-District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, Satpuli, Near Saint Paul Hospital Pauri Garhwal

Test Report ID: 02/ UJS/SDLWQTMLS/2025-2026

Dated: 26/05/2025

**WATER QUALITY TEST REPORT**

Name and Address Of Organization/ Customer:	Atal Uttkrist Govt. Inter College, Kanskhet		
Type of Source : (Surface Water/Ground water/ Drinking water)	Drinking Water	Sample Description:	One Water Sample collected from Atal Uttkrist Govt. Inter College, Kanskhet
Reference Sample Identification:	SDLWQTMLS/AURIC-01		Date of Start of Analysis: 24/05/2025
			Date of End of Analysis: 26/05/2025
Date & Time of Sample Received: 24/05/2025, 2.45pm	Sample Collected by:	Customer	

S.N	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)	Std. Test Method
1.	Colour, Hazen, Max	1.0	5	15	IS 3025 (Part 04): 2017
2.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05-2018
3.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 08): 2017
4.	pH at 25° C	7.76	6.5 to 8.5	No Relaxation	IS 3025 Pt-11-2017
5.	Turbidity, NTU, Max	0.31	1	5	IS 3025 Pt-10-2017
6.	Total Dissolved Solids (TDS), mg/L, Max	155	500	2000	IS 3025 Pt-16-2017
7.	Chloride, mg/L, Max	7.48	250	1000	IS 3025 (Part 32): 2019
8.	Total Hardness (as CaCO <sub>3</sub> ), mg/L, Max	76	200	600	IS 3025 (Part 21): 2019
9.	Calcium (as Ca), mg/L, Max	21.6	75	200	IS 3025 (Part 40): 2019
10.	Magnesium (as Mg), mg/L, Max	5.346	30	100	APHA 23rd Ed.-3500-Mg.B-2017
11.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L, Max	64	200	600	IS 3025 (Part 23): 2019
12.	Residual Free Chlorine, mg/L, Max	0.1	0.2	1.0	APHA 23rd Ed.-4500-Cl-G
<b>Bacteriological Parameters</b>					
13.	E.Coli, MPN/ 100 ml	0.0	Absent	Absent	APHA 23 <sup>rd</sup> Ed.-9223-B
14.	Total Coliform, MPN/100ml	0.0	Absent	Absent	APHA 23 <sup>rd</sup> Ed.-9223-B

दीपक सिंह

अध्यक्ष

विद्यालय प्रबंधन समिति

प्रधानाचार्य

सं. उत्कृष्ट रा० ड० का० कास०  
कल्पीखाल, पौड़ी गढ़वाल

TECHNICAL MANAGER  
SUB-DIVISIONAL LEVEL  
WATER QUALITY TESTING  
MONITORING LABORATORY Charge  
Uttarakhand Jal Sansthan, Satpuli